

ADDENDUM No. 3
Request for Proposals (RFP)
20RFP003 Notification and Scheduling System

August 7, 2019

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Summary of Walk Through on July 29, 2019

A summary of the walk through has been attached to the end of this addendum.

Item 2: Questions and Answers

1) Div275319- On the 3 new schools, are IP speakers currently installed? And are they Informacast enabled?

a. Answer: No speakers are installed for the purpose of PA and/or Intercom

2) Div275319- On the 3 new schools, are there currently analog speakers installed? Are they 70/100 volt system?

a. Answer: No speakers are installed for the purpose of PA and/or Intercom

3) Div275319- What head end unit is being used at each school?

a. Answer: No PA or Intercom equipment is installed at the school, including head end units.

4) :RXOG LW SOHDVH EH SRVVLEOH IRU XV WR REWDLQ D
Div 27 Cabling Contractor who ran the wire / cabling during the construction of these three
(3) schools being bid? Explanation:, X QGHUVWDQG WKHVH DUH WKH 5)
basically are bidding per the information on the Appendix A Appendix A shows the
quantity of classroom speakers and hallway speakers and outside speakers. But we are
KDYLQJ WR 3DVVXPH WKH ZLUH DQG FDEOH IRU WKHVH
4 IDF closets in each school. So, when we itemized and price out the system, we could
HQQ XS EHLQJ 32))' DQG 3:52 1f*W HL Q DRG W KH W \$ P D\XHL OW '
it would show the number of wire / cables going from the classrooms, hallways and exterior
and we would know for sure which IDF they are in and how many cables are in each IDF.

a. Answer: : H G R Q ¶ W KIDU Documents Det

- a. Answer: A minimum of 2 key personnel will need to be trained on campus.
- 19) Do the speakers in classrooms and offices need a push button to initiate calls?
 - a. Answer: No.
- 20) What kind of speakers are required for the cafeteria and kitchen?
 - a. Answer: The type of speaker will vary primarily by the building layout and ceiling heights. The specifics on what type of speakers to be utilized are included in Appendix D.
- 21) Do you have a preferred speaker vendor?
 - a. Answer: No

GOVALLE ELEMENTARY SCHOOL

- 1 ±Outdoor speaker locations will they have conduit access provided? Answer: Yes
- 2 ±Outdoor speaker locations if conduit provided size of conduit? Answer: ¾ inch
- 3 ±Outdoor speaker locations will they have covered job boxes for mounting? Answer: We are only providing a recessed, single gang, electrical box.
- 4 ±Outdoor speaker locations if they have job boxes can we receive the cut sheet / specifications of these job boxes? \$ Q V Z H U , G R Q R W E H O L H Y H Z H D U H S U R Y L G L Q J : needs to be a box to house the speaker and other equipment the vendor will need to provide it with their submitted proposal.
- 5 ±Gym speaker locations will they have conduit access provided? Answer: Yes, in walls or open ceiling areas.
- 6 ±Gym speaker locations if conduit provided size of conduit? Answer: ¾ inch
- 7 ±Gym speaker locations if no conduit will they require raceway, hook, or in wall cable runs for cabling? Answer: hook and cable tray will be available for running above ceilings
- 8 ±Gym speaker locations will they have covered job boxes for mounting? Answer: We are only providing a recessed, single gang, electrical box.
- 9 ±Gym speaker locations if they have job boxes can we receive the cut sheet / specification of these job boxes? \$ Q V Z H U , G R Q R W E H O L H Y H Z H D U H S U R Y L G L Q J : box to house the speaker and other equipment the vendor will need to provide it with their submitted proposal.
- 10 ±Cafeteria speaker locations will they have conduit access provided? Answer: Yes, if required

Any additional speakers can be taken care of after vendor(s) are selected and a final SOW is agreed upon.

MENCHACA EL EMENTARY SCHOOL

- 1 ±No Key is provided on PDF documents can we receive an updated PDF to ensure specifications of interior and exterior speakers?
Answer: We will upload a key/legend for each F D P S X V L I L W V P L V V L Q J \$ W W D F K R H Q W ' W E K R Y O A B K D Y H W K H requirements. The PDFs of the campus maps or drawings should have a page with the speaker locations and speaker types.
- 2 ±Outdoor speaker locations will they have conduit access provided?
Answer: Yes
- 3 ±Outdoor speaker locations if conduit provided size of conduit?
Answer: ¾ inch
- 4 ±Outdoor speaker locations will they have covered job boxes for mounting?
Answer: We are only providing a recessed, single gang, electrical box.
- 5 ±Outdoor speaker locations if they have job boxes can we receive the cur sheet / specifications of these job boxes?
Answer: Q V Z H U , G R Q R W E H O L H Y H Z H D U H S U R Y needs to be a box to house the speaker and other equipment the vendor will need to provide with their submitted proposal.

~~CM~~

~~2013~~

~~01/29~~2019

Site Walkthrough Started: 3:10 p.m.

Attendees:

- x John Greiner t Austin ISD
 - x Joseph Molina t Austin ISD
 - x **Joseph Pille** Menchaca Construction Manager
 - x Billy Nantz - TerraBridge IT
-

Q1. How many campuses will we be do a walkthrough for today?

A1. John Greiner t Just the 1, Menchaca.

Q2. What type of paging system are you using?

A2. John Greiner t We are using a Telecor, not the IP based solution, but the older offline version.

Q3. Are you staying with Telecor?

A3. John Greiner t

A7. The classrooms will be dropped ceiling tile, and there are opens ceilings in the large common areas, painted white.

Q8. What is the intended use of Studio 17 as an open collaborations or flex space?

A8. John Greiner -

