

**ADDENDUM No. 2**  
**Request for Competitive Sealed Proposals (CSP)**  
**20CSP043 Upgrades at Winn Elementary School**

October 21, 2019

Received by bidder:

Date: \_\_\_\_\_

Name: \_\_\_\_\_

Signature: \_\_\_\_\_

**Item 1: Questions and Answers**

Question: On the roofing plans R-100 it has a detail for roof guardrail that is penetrating the roof system at the edge metal. Then in the specifications (077200) it is asking for a non penetrating guardrail system. Leading Edge provides both types of guardrailing. Which railing system should i use to bid this project?

**Item 2 : Clarification**

**ADDENDUM NO. 02**

**PROJECT** Austin ISD  
(AISD # 19-0002)  
3500 Susanna Lane  
Austin, Texas 78743

**PROJECT NO.** 19002

**DATE** October 21, 2019

**TO:** All Prime Contract Bidders and all other interested parties. All drawings and specifications have been issued by the Architect/Engineer.

This Addendum forms part of the Contract Documents as follows to the above mentioned project. All provisions of the Documents shall remain in the same order.

**CLARIFICATIONS**

**ITEM NO. 1 BID QUESTION**

- A. The note on the roof plan indicates that the roof is to be installed under edge metal as referenced in Detail (1/D100). Not permitted through the roof. Penetrating through the roof will not be allowed.

**CHANGES TO THE SPECIFICATIONS**

**ITEM NO. 2 Austin ISD - Project Development - Movement from Modern Learning Environment**

- A. The Project Development is included in the specification. This is only for general reference and not beneficial to the project.

- 0 0 0 -

W:\19002\_AISD Winn E.S\19-0\_Bidding\Addendum No. 02.rvt

