

ADDENDUM No. 4
Competitive Sealed Proposal (CSP)
21CSP011 Replace Fire Control Panels District Wide

July 27th, 2020

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Questions and Answers

Item 2: Changes to Specifications

Item 1: Questions and Answers:

Q: We will need to know what locations have the previously approved plans available. Any locations that have the stamped drawings will only need a letter to the AHJ, the ones that do not will need CAD files for a submittal to the AHJ

A: All available Fire Alarm drawings are provided <https://planroom.millerids.com> as part of this addendum, titled: "Project Sites Fire Alarm Drawings"

Q: Please verify that each Group location shown to currently have ~~500~~ 1000 on the Support Document 3 \$, 6 ') LUH \$ O D U P ' H Y L F H & R X Q W ' L V W R E H S U R S R V H G D V U H F H L Y within 1. Project 1.1. Scope of Work

A: Please provide pricing based on the device quantities listed in the AISD Fire Alarm Device Count document.

Q: Please verify that each Group location shown to currently have ~~at 1000~~ 1000 on the Support Document 3 \$, 6 ') LUH \$ O D U P ' H Y L F H & R X Q W ' L V W R E H S U R S R V H G D V U H F H L Y within 1. Project 1.1. Scope of Work.

A: Please provide pricing based on the device quantities listed in the AISD Fire Alarm Device Count document.

Q: Please verify that each Group location shown to currently have 1000 VIP on the Support 'RFXPHQW 3\$,6')LUH \$ODUP proposed as being the exact same as listed within 1. Project 1.1. Scope of Work not an-2000 ECS

A: There has been change to the specifications listed in the Solicitaton for please refer to the "Changes to Specifications", Item 2 on this Addendum for the updated specifications. IFP1000 will now be replaced by the IFP 2100 upgrade. IFP1000 VIP will be replaced by the IFP2100 ECS. upgrade

Q: Please clarify that any additional equipment discovered to require upgrade will be priced in addition to

4000 S IH 35 Frontage Road, Austin Texas, 78704, 4

Page 3, ^ š}}v íXíU ^^ }%Jpd}est }CEI_

1. Additional Scope added to the Scope of Work description
 - f Install updated version of existing annunciator if required
2. Additional Scope added under the Honeywell SK5820 Fire Control System v•š o o š}}v
 - Replace Existing 350 Annunciator Scope of work to include submit required documents and obtain required approvals from Austin Fire Dept. prior to beginning of work. Identification of existing 350 Annunciator

3. Updated specifications for the Honeywell IFP1000 Fire Control Panel
- f Replace existing Honeywell IFP1000 Fire Control Panel with Honeywell IFP2100 Fire Control Panel
 Quantity: 1
 - f Replace existing Honeywell IFP1000 Fire Control Panel with Honeywell IFP2100 Fire Control Panel
 Quantity: 1
 - f Install 120V GT Hybrid Surge Protection Device on input power at new Honeywell IFP2100 or IFP2100 Fire Control Panel
 Quantity: 1
 - f Install ELOCK Circuit Breaker Lockout for new Honeywell IFP2100 or IFP2100 Fire Control Panel
 Quantity: 1